

# All India Institute of Medical Sciences

(Ministry of Health & Family Welfare, Government of India)

Bhubaneswar (Odisha) - 751 019

Date :17/12/2025

## CORRIGENDUM – 2

Tender Ref No: AIIMS/BBSR/ENGG. /ELECT. /76/2025

Published Date: 21.11.2025

Name of the Work : SITC of High mast in the main play ground near type- 2B  
Housing Complex, AIIMS, Bhubaneswar.

The specifications in the NIT Document and bid submission dates are changed as follows:

Description	Existing	To be read as
Clause 1/5 of Specification and preferred make (Page No-16)	The mast shaft shall be manufactured from high tensile steel plates confirming to IS 2062/ BS EN 10025 having minimum yield strength of (Grade 65) 450N/Sq.mm and silicon content less than 0.06 %.	The mast shaft shall be manufactured from high tensile steel plates confirming to IS 2062(E-350)/ BS EN 10025(S-355) having minimum yield strength of 350 N/Sq.mm and silicon content less than 0.06 %.
Clause 1/14 of Specification and preferred make(Page No-17)	For base plate and foundation bolt as per IS 2062: 2011, Gr E350 A , hot dip galvanized as per IS 4759: 1996/ IS 2629: 1985, Base plate and foundation bolts steel Grade is -IS2062,2011, Gr E350A.	For base plate and foundation bolt as per IS 2062, Gr E 250 ,IS 1367 Gr 6.8 or equivalent respectively , hot dip galvanized as per IS 4759: 1996/ IS 2629: 1985.
Annexure-I Point no-31 (Page No-24)	Cover type: Heat Resistant Toughened glass of minimum 4 mm thick or UV stabilized polycarbonate cover.	Cover type: Heat Resistant Toughened glass of minimum 4 mm thick .


**Additional clarifications-**

1. Cost of Control gear rack and necessary wiring from control rack to lighting fixture is included in the cost of luminaries.
2. Payment will be made as per actual measurement at site.
3. Minor Horticulture/Civil work is under the scope of the agency.
4. No EMD exemption is allowed in this tender.
5. Please read the price mentioned at financial bid (BA) column as price including GST.

**Note :**

- i) All Terms/ Conditions/ Specification mentioned in the e-Tender documents, corrigendum & price Bid shall remain same and unchanged, except the above.

Website : [www.aiimsbhubaneswar.nic.in](http://www.aiimsbhubaneswar.nic.in)  
<https://eprocure.gov.in/eprocure/app>

  
EE, Electrical  
AIIMS, Bhubaneswar  
Executive Engineer (Electrical)  
AIIMS, Bhubaneswar