



All India institute of Medical Sciences
Ministry of Health & Family Welfare, Government of India
Bhubaneswar (Odisha) - 751 019
Engineering-AC&R

ADDENDUM

Address for Submission of Hard Copy of Documents

Office of the Executive Engineer (AC&R)
Room No. 122, 1st Floor, Academic Building
AIIMS, Bhubaneswar
Sijua, Patrapada, Bhubaneswar – 751019

Independent External Monitor (IEM)

Shri Anup Kumar Srivastava

Flat No. 1406, Pavilion Heights
Sector-128, Noida
Gautam Budh Nagar
Uttar Pradesh – 201304
Email: priyanup@yahoo.com

Corrigendum

Existing Provision	To be Read As
Nit page no -20, Technical specification- Outdoor Units from more than 18 HP should consist of the combination of 2 or 3 base units. Each outdoor unit should have minimum 1 no. Inverter with variable speed compressor up to 18HP	Outdoor Units from more than 14 HP should consist of the combination of 2 or 3 base units. Each outdoor unit should have minimum 1 no. Inverter with variable speed compressor up to 14HP

All other terms and conditions of the tender shall remain unchanged.

S/d
Executive Engineer (AC & R)
AIIMS, Bhubaneswar